

## South Butler County School District

### Lead and Copper Sampling Results - High School / Middle School

Orange highlight indicates result is over 1/2 of DEP Action Level	Yellow highlight indicates result is at/over the DEP Action Level	PA DEP Copper Action Level - 1.3 mg/L	PA DEP Lead Action Level - 0.015 mg/L
Sample Date	Location	Copper Result (mg/L)	Lead Result (mg/L)
5/26/2017	300 Hall Fountain by Guidance	0.123	<0.001
5/26/2017	009 Chem Lab Sink	0.657	0.004
5/26/2017	Room 317 Home Economics #1 Door	0.272	0.005
5/26/2017	Room 317 Home Economics #2	0.465	0.015
5/26/2017	Room 317 Home Economics #3 Left	0.798	0.119
5/26/2017	Room 317 Home Economics #4 Right	0.565	0.104
5/26/2017	Room 319 Life Skill #1 Demo	0.766	0.024
5/26/2017	Room 319 Life Skills #2 Door	0.920	0.029
5/26/2017	Room 319 Life Skills #3	0.437	0.014
5/26/2017	Room 319 Life Skills #4	0.808	0.033
5/26/2017	Room 322 Fountain	0.103	<0.001
5/26/2017	Room 326 Sink	0.657	0.016
5/26/2017	Junior High Cafeteria Fountain #1 Right	0.254	0.003
5/26/2017	Junior High Cafeteria Fountain #2 Left	0.211	<0.001
5/26/2017	Room 434 Sink	0.219	0.005
5/26/2017	051 Sink	0.332	0.003
5/26/2017	Girls Locker Room Fountain	0.121	<0.001
5/26/2017	Boys Locker Room Fountain	0.097	<0.001
5/26/2017	Boys Locker Room Office Sink	0.159	<0.001
5/26/2017	Gym Concession Sink	0.425	<0.001
5/26/2017	AD Office Sink	0.112	<0.001
5/26/2017	Trainer Room Downstairs Sinks FCR #1 Left	0.184	<0.001
5/26/2017	Trainer Room Downstairs Sinks/FCR#2 Right	0.263	<0.001
5/26/2017	Trainer Room Downstairs FCR #3 Ice	0.023	<0.001
5/26/2017	Boys Locker Downstairs Fountain	0.163	<0.001
5/26/2017	Gym Fountain #1	0.163	<0.001
5/26/2017	Gym Fountain #2	0.154	<0.001
5/26/2017	Kitchen Sinks #1 Left	0.255	0.006
5/26/2017	Kitchen Sink Right #2	0.190	0.002
5/26/2017	Soup Kettle #3	0.162	<0.001
5/26/2017	Room 516 Outside Room Fountain	0.108	<0.001
5/26/2017	Room 505 Sink	0.218	0.001
5/26/2017	Room 503 Sink	0.371	0.004
5/26/2017	Room 501 Sink #1 Desk	0.569	0.005
5/26/2017	Room 501 Sink #2	1.49	0.010
5/26/2017	Room 501 Fountain	0.109	<0.001
5/26/2017	Nurse's Office Sink	0.114	<0.001
5/26/2017	Nurse's Office Fountain Outside	0.091	<0.001
5/26/2017	Room 412 Teachers Sink	0.320	0.020
5/26/2017	Room 409 Teachers Sink	0.335	0.002
5/26/2017	Room 411 Teachers Sink	0.415	0.002
5/26/2017	Room 414 Teachers Sink	0.691	0.014
5/26/2017	Room 413 Sink	0.536	0.009
5/26/2017	Room 418 Sink - Right	0.610	<0.001
5/26/2017	Room 417 Teachers Sink	0.309	0.004
5/26/2017	Room 417 Fountain	0.135	<0.001
5/26/2017	Custodian Sink	0.130	<0.001
5/26/2017	Office Sink	0.139	<0.001
5/26/2017	020 Art Room Sink	0.140	<0.001
5/26/2017	HS Library	0.174	<0.001

5/26/2017	109 Teachers Spigot	0.527	0.001
5/26/2017	110 Teachers Spigot	0.740	0.002
5/26/2017	001 Restroom Fountain Right	0.193	<0.001
5/26/2017	001 Restroom Fountain Left	0.230	<0.001
5/26/2017	005 Restroom Fountain Left	0.125	<0.001
5/26/2017	005 Restroom Fountain Right	0.144	<0.001
5/26/2017	Room 124 Teachers Sink	0.249	0.001
5/26/2017	Room 125 Teachers Sink	2.45	0.046
5/26/2017	134-135 Boys Restroom Fountain #1	0.185	<0.001
5/26/2017	134-135 Girls Restroom Fountain #2	0.243	<0.001
5/26/2017	Room 134 Teachers Sink	0.882	0.007
5/26/2017	Room 135 Art Room Sink #1	0.336	<0.001
5/26/2017	Room 135 Art room Sink #2	0.310	<0.001
5/26/2017	Library	0.149	<0.001
5/26/2017	Gym Converted Bath Across 011 #1	0.077	<0.001
5/26/2017	Gym Converted Bath Across 011 #2 Ice Maker	<0.010	<0.001
5/26/2017	012 Weight Room	0.285	0.079
5/26/2017	Locker Room Outside Tap	0.240	0.015
5/26/2017	Boys Locker Room Gym Fountain	0.096	<0.001
5/26/2017	Room 215 Sink	0.156	<0.001
5/26/2017	Kitchen	0.149	0.001
5/26/2017	Girls Locker Room Fountain	0.144	<0.001
5/26/2017	Cafeteria Fountain	0.298	0.002
5/26/2017	208-210 Restroom Fountain Left	0.148	0.003
5/26/2017	208-210 Restroom Fountain Right	0.121	0.002
5/26/2017	Room 207 Art Room Sink	0.101	<0.001
5/26/2017	Nurses Office Sink #1 Elem Room	0.520	<0.001
5/26/2017	Nurses Office Sink #2 Desk	0.204	<0.001
5/26/2017	Nurses Office Sink #3 Bathroom	0.137	<0.001
5/26/2017	Room 204 Home Economics Demo Desk	0.178	<0.001
5/26/2017	Room 204 Home Economics #1	0.154	<0.001
5/26/2017	Room 204 Home Economics #2	0.123	<0.001
5/26/2017	Room 204 Home Economics #3	0.138	<0.001
5/26/2017	Room 204 Home Economics #4	0.096	<0.001
5/26/2017	General Office Sink	0.276	0.003
5/26/2017	Girls Locker Downstairs Fountain	1.03	0.008