

## South Butler County School District

### Lead and Copper Sampling Results - Primary Elementary

Orange highlight indicates result is over 1/2 of DEP Action Level	Yellow highlight indicates result is at/over the DEP Action Level	PA DEP Copper Action Level - 1.3 mg/L	PA DEP Lead Action Level - 0.015 mg/L
Sample Date	Location	Copper Result (mg/L)	Lead Result (mg/L)
5/26/2017	Admin Conf Sink	0.087	<0.001
5/26/2017	Admin Conf Bubbler	0.139	<0.001
5/26/2017	Room 212 Sink	0.981	0.003
5/26/2017	Room 212 Bubbler	0.588	0.001
5/26/2017	Room 210 Sink	0.267	<0.001
5/26/2017	Room 210 Bubbler	0.176	<0.001
5/26/2017	Room 208 Sink	0.850	<0.001
5/26/2017	Room 208 Bubbler	0.213	0.001
5/26/2017	Room 209 Sink	0.169	<0.001
5/26/2017	Room 209 Bubbler	0.077	<0.001
5/26/2017	Room 207 Sink	0.146	<0.001
5/26/2017	Room 207 Bubbler	0.087	<0.001
5/26/2017	Boys Restroom Fountain Right	0.060	<0.001
5/26/2017	Girls Restroom Fountain Right	0.068	<0.001
5/26/2017	Room 206 Sink	0.181	<0.001
5/26/2017	Room 206 Bubbler	0.105	<0.001
5/26/2017	Room 205 Sink	0.113	<0.001
5/26/2017	Room 205 Bubbler	0.069	<0.001
5/26/2017	Room 204 Sink	0.165	<0.001
5/26/2017	Room 204 Bubbler	0.087	<0.001
5/26/2017	Room 203 Sink	0.112	<0.001
5/26/2017	Room 203 Bubbler	0.072	<0.001
5/26/2017	Room 202 Sink	0.164	<0.001
5/26/2017	Room 202 Bubbler	0.118	<0.001
5/26/2017	Room 201 Sink	0.159	<0.001
5/26/2017	Room 201 Bubbler	0.065	<0.001
5/26/2017	Room 431 Sink	0.799	<0.001
5/26/2017	Room 431 Bubbler	1.120	<0.001
5/26/2017	Room 301 Sink	0.152	<0.001
5/26/2017	Bathroom by 201	0.517	<0.001
5/26/2017	General Office Sink	0.170	<0.001
5/26/2017	General Office Bubbler	0.180	<0.001
5/26/2017	Nurse's Office Exam Sink	0.732	<0.001
5/26/2017	Nurse's Office Exam Bubbler	0.249	<0.001
5/26/2017	Nurse's Large Exam Sink	0.114	<0.001
5/26/2017	Nurse's Large Exam Bubbler	0.087	<0.001
5/26/2017	Music Room Sink	0.163	<0.001
5/26/2017	Music Room Bubbler	0.076	<0.001
5/26/2017	Boys/Girls Restroom Fountain 409	0.063	<0.001
5/26/2017	Room 409 Sink	0.274	<0.001
5/26/2017	Room 409 Bubbler	0.132	<0.001
5/26/2017	K01 Sink	0.152	<0.001
5/26/2017	K01 Bubbler	0.155	<0.001
5/26/2017	K02 Sink	0.195	<0.001
5/26/2017	K02 Bubbler	0.149	<0.001
5/26/2017	K03 Sink	0.124	<0.001
5/26/2017	K03 Bubbler	0.113	<0.001
5/26/2017	K04 Sink	0.112	<0.001
5/26/2017	K04 Bubbler	0.107	<0.001
5/26/2017	K05 Sink	0.134	<0.001
5/26/2017	K05 Bubbler	0.138	<0.001
5/26/2017	K06 Sink	0.126	<0.001
5/26/2017	K06 Bubbler	0.107	<0.001
5/26/2017	Room 401 Sink	0.018	0.003

5/26/2017	Room 401 Bubbler	0.113	0.003
5/26/2017	Room 101 Sink	0.243	<0.001
5/26/2017	Room 101 Bubbler	0.109	<0.001
5/26/2017	Room 102 Sink	0.114	<0.001
5/26/2017	Room 102 Bubbler	0.092	0.003
5/26/2017	Room 103 Sink	0.108	0.003
5/26/2017	Room 103 Bubbler	0.089	0.003
5/26/2017	Room 104 Sink	0.111	0.003
5/26/2017	Room 104 Bubbler	0.089	0.003
5/26/2017	Room 105 Sink	0.097	0.003
5/26/2017	Room 105 Bubbler	0.098	0.003
5/26/2017	Room 106 Sink	0.169	0.001
5/26/2017	Room 106 Bubbler	0.101	<0.001
5/26/2017	Room 107 Sink	0.110	<0.001
5/26/2017	Room 107 Bubbler	0.096	<0.001
5/26/2017	Room 108 Sink	0.105	<0.001
5/26/2017	Room 108 Bubbler	0.103	<0.001
5/26/2017	Room 109 Sink	0.142	<0.001
5/26/2017	Room 109 Bubbler	0.119	<0.001
5/26/2017	Room 110 Sink	0.141	<0.001
5/26/2017	Room 110 Bubbler	0.111	<0.001
5/26/2017	Room 112 Sink	0.419	<0.001
5/26/2017	Room 112 Bubbler	0.163	<0.001
5/26/2017	Room 410 Sink	0.096	<0.001
5/26/2017	Gym Fountain	0.139	<0.001
5/26/2017	Cafeteria Fountain	0.132	<0.001
5/26/2017	Kitchen Prep Sink and Soap - By Register	0.580	<0.001
5/26/2017	Kitchen Prep Sink and Soap - By Office	0.214	<0.001
5/26/2017	Kitchen Prep Sink and Soap - Dish Wash Left	0.296	0.003
5/26/2017	Kitchen Prep Sink and Soap - Dish Wash Right	0.522	0.027
5/26/2017	Room 301 Bubbler	0.082	<0.001
5/26/2017	Room 302 Sink	0.119	<0.001
5/26/2017	Room 302 Bubbler	0.067	<0.001
5/26/2017	Room 303 Sink	0.217	<0.001
5/26/2017	Room 303 Bubbler	0.079	<0.001
5/26/2017	Room 304 Sink	0.110	<0.001
5/26/2017	Room 304 Bubbler	0.059	<0.001
5/26/2017	Room 305 Sink	0.212	<0.001
5/26/2017	Room 305 Bubbler	0.101	<0.001
5/26/2017	Room 306 Sink	0.122	<0.001
5/26/2017	Room 306 Bubbler	0.065	<0.001
5/26/2017	Girls 3rd Restroom Fountain	0.108	<0.001
5/26/2017	Boys 3rd Restroom Fountain	0.139	<0.001
5/26/2017	Room 307 Sink	Sample bottle broken during transit	
5/26/2017	Room 307 Bubbler	0.101	<0.001
5/26/2017	Room 308 Sink	0.115	<0.001
5/26/2017	Room 308 Bubbler	0.057	<0.001
5/26/2017	Room 309 Sink	0.125	<0.001
5/26/2017	Room 309 Bubbler	0.097	<0.001
5/26/2017	Room 310 Sink	0.125	<0.001
5/26/2017	Room 310 Bubbler	0.066	<0.001
5/26/2017	Room 311 Sink	0.796	<0.001
5/26/2017	Room 311 Bubbler	1.06	<0.001
5/26/2017	428 Teacher's Lounge	Sample tap had been used in morning - no sample	
5/26/2017	Room 423 Sink	0.690	0.003
5/26/2017	Room 423 Bubbler	No sample collected	
5/26/2017	Main Hall 2nd/3rd Restroom Fountain	0.051	<0.001
5/26/2017	Room 421 Art Room Sink	0.167	<0.001
5/26/2017	Room 421 Art Room Bubbler	0.097	<0.001
5/26/2017	Library Work Room Sink	0.231	<0.001